

Data Sheet 504

Unitest Aeration Control



A special version of the Unitest® 3000W software contains an aeration control system, which has two different modes of operation.

Manual Mode

This mode allows the operator to start and stop the aeration fans manually.

Automatic Mode

The automatic mode starts the aeration fans on basis of the following parameters, which can be set individually by the operator:

- Delta temperature
- Minimum grain temperature
- Minimum outdoor temperature
- Maximum outdoor air humidity
- Time of the day when fans are to start

Basically the system is available in two versions:

Unitest® 3000WT

Temperature monitoring

Unitest® 3000WTA

Temperature monitoring and aeration control.

Copyright © - The right to alterations is reserved